


Customer: valued Ludeca Customer Inspector: Brian Franks  
 Asset: Blaster fan Filename: Fan #9 Job #1.srbain  
 Printed on: 01/08/2015 15:50:29 Measured on: 12/11/2014 10:18:38

Task: #9 fan-Channel A Measurement setup: Phase Vel.1  
 Sensor Setup: VIB 6.146

Polar Display



Balancing steps

No.	Weight [g]	Angle [°]	Vibration 0-P [inch/s]	Angle [°]	Revolution [rpm]
0	---	---	0.064	349	3199
* 1	2.0	139	0.086	271	3199
2	1.3	78	0.001	25	3198
3	0.0	113	---	---	---

**Machine info**

Machine name: #9 fan  
Target balance quality: 1.00  
Current balance quality: 0.1715 @ 3198 rpm